

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER
CHEMICAL OR RADIOLOGICAL MAXIMUM CONTAMINANT
LEVEL (MCL) EXCEEDANCE

ESTE INFORME CONTIENE INFORMACIÓN IMPORTANTE ACERCA DE SU AGUA POTABLE. HAGA QUE ALGUIEN LO TRADUZCA PARA USTED, O HABLE CON ALGUIEN QUE LO ENTIENDA.

Montoursville Borough Waterworks Has Levels of Fluoride
Above Drinking Water Standards

Our water system recently violated a drinking water standard. Although this incident was not an emergency, as our customers, you have a right to know what happened and what we did to correct this situation.

We routinely monitor for drinking water contaminants. Testing results we received on 9/21/2021 show that our system exceeds the standard, or maximum contaminant level (MCL), for Fluoride. The standard for Fluoride is 2.0 mg/L. Fluoride was found at 4.4 mg/L.

What should I do?

You do not need to use an alternative (e.g., bottled) water supply. However, if you have specific health concerns, consult your doctor.

What does this mean?

This is not an immediate risk. If it had been, you would have been notified immediately. However, long term effects could be bone disease or mottled teeth in children after extended use.

What happened? What was done?

Montoursville Borough Waterworks completed compliance monitoring for Fluoride on 8-18-2021. The results came back on 9-21-2021 with a level of Fluoride that exceeds the MCL of 2.0 mg/L. We retested a sample on 10-7-2021 and the test came back <0.040 mg/L. Fluoride. We will monitor Fluoride quarterly to monitor Fluoride levels. We anticipate resolving the problem within the next 4 quarters.

For more information, please contact Clifford A. Hoffman at 570-506-3034.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by Montoursville Borough Waterworks.